

Sec. 34-518 (1)(c)

A generator of grease trap waste or grit trap waste shall have traps serviced as frequently as necessary to prevent bypass or overflow, and to ensure proper operation of the trap. Such generators shall, at a minimum, have grease traps and grit traps serviced quarterly or as approved by the Control Authority in accordance with all other provisions of this division.