

PART II - CODE
Chapter 34 - WATER AND SEWERS
ARTICLE V. - SEWAGE TRANSPORTATION, TREATMENT AND DISPOSAL
DIVISION 5. FATS, OILS AND GREASE

DIVISION 5. Fats, Oils and Grease.

Sec. 34-525. General provisions.

- (c) *Definitions.* As used anywhere in this division, the following terms are defined to mean:

City Code: The City of San Antonio, Texas Code of Ordinances.

Sec. 34-526. Interceptors.

- (b) *Interceptor required.* Each FSE and FPE shall discharge all waste from sinks, dishwashers, drains, and any other fixtures or sources through which fats, oils, or grease may be discharged into the POTW into a properly maintained and functioning interceptor that complies with the requirements of Chapter ~~2410~~, of the City Code of Ordinances and the International Plumbing Code and appendices as amended that are adopted by the City in that chapter.
- (c) *Existing facilities.* Existing FSEs and FPEs that are not equipped with an interceptor that complies with the requirements of Chapter ~~2410~~, of the City Code of Ordinances and the International Plumbing Code and appendices as amended that are adopted by the City in that chapter shall install such an interceptor not later than one hundred and eighty (180) days after the effective date of the ordinance from which this division derives.
- (d) *New facilities.* New FSEs and FPEs shall be equipped with an interceptor that complies with the requirements of Chapter ~~2410~~, of the City Code of Ordinances and the International Plumbing Code and appendices as amended that are adopted by the City in that chapter prior to commencement of any discharge into the POTW.

Sec. 34-529. Prohibitions.

- (b) *Removed interceptor waste.* Liquids removed from an interceptor that has a capacity equal to or less than 100 gallons may be returned to an interceptor that complies with the requirements of this Division. Grease, solids, or any matter other than liquids removed from an interceptor that has a capacity equal to or less than 100 gallons shall not be returned to an interceptor and shall not be disposed of in any private sanitary sewer line or any portion of the POTW and must be disposed of in a facility that is authorized by law to receive such wastes. Liquids removed from an interceptor that has a capacity equal to or less

PART II - CODE
Chapter 34 - WATER AND SEWERS
ARTICLE V. - SEWAGE TRANSPORTATION, TREATMENT AND DISPOSAL
DIVISION 5. FATS, OILS AND GREASE

than 100 gallons that are not returned to an interceptor shall not be disposed of in any private sanitary sewer line or any portion of the POTW and must be disposed of in a facility that is authorized by law to receive such wastes. Grease, solids, liquids, or any other matter removed from an interceptor that has a capacity greater than 100 gallons shall not be returned to any interceptor, or disposed of in any private sanitary sewer line, any portion of the POTW, or any location other than a facility that is authorized by law to receive such wastes.