

Sec. 34 - 131 (c)(1)

(c) Requirements for fire hydrant meter periodic calibration and meter readings. A customer authorized by SAWS to use a fire hydrant meter must meet the following requirements:

(1) Return the meter to SAWS for inspection and re-calibration every twelve (12) months from the original date of the customer's fire hydrant meter contract; if the customer fails to meet this requirement, the customer will