

August 29, 2016

2017 MAR -9 PM 2: 39

Mr. Elseth Travis KFW Engineers 3421 Paesanos Pkwy., Suite 200 San Antonio, Texas 78231

RE: File No. 1608003 - Request for review of Wortham Oaks Unit 18 & 19 (Enclave), Plat No. 160419 located southeast of Akin Town & southwest of Akin Nook.

Dear Mr. Travis:

On August 25, 2016, the Aquifer Protection & Evaluation Section of the Edwards Aquifer and Watershed Protection Division of the San Antonio Water System (SAWS) received a request to review a plat for the property referenced above. Staff reviewed the documentation submitted and conducted field observations of the referenced plat to ensure compliance with applicable requirements for development over the Edwards Aquifer Recharge Zone (EARZ). The land use of the subject plat is for residential and consists of approximately 15.631 acres located entirely within the EARZ. No sensitive geological features were observed. The property is not within the 100-year floodplain preservation area.

The proposed development is a **Category 1** property under the provisions of Aquifer Protection Ordinance No. 81491-File No.2121, 1735. Certain changes to the project may create a substantial alteration to the provision of the Water Quality Ordinance and alter its category.

A Water Pollution Abatement Plan (WPAP) has been submitted to the Texas Commission on Environmental Quality (TCEQ) and approved in their letter dated June 12, 2012.

After careful review of the project and the documentation submitted by the applicant, the Aquifer Protection & Evaluation Section of the Edwards Aquifer and Watershed Protection Division of the San Antonio Water System (SAWS), recommends the **approval** of Wortham Oaks, Unit 18 & 19 (Enclave), Plat No. 160419.

If you have any questions regarding this matter, please contact the Aquifer Protection & Evaluation Section at (210) 233-3516.

Sincerely

Andrew Wiatrek, Manager

Edwards Aquifer & Watershed Protection Division

AW. Ird

production of the second