#### HISTORIC AND DESIGN REVIEW COMMISSION

August 02, 2017

2017-217
1111 E CROCKETT ST
NCB 578 BLK D LOT W32.83 FT OF E 65.66 FT OF 5 ARB A7 AT 1111 CROCKETT ST E
RM-4, H
2
Dignowity Hill Historic District
Felix Ziga/Studio Ziga
Henneke Financial Group, LLC
Construction of a two story, single family residential structure

#### **REQUEST:**

The applicant is requesting a Certificate of Appropriateness for approval to construct a two story residential structure on the vacant lot at 1111 E Crockett.

#### **APPLICABLE CITATIONS:**

Historic Design Guidelines, Chapter 4, Guidelines for New Construction

1. Building and Entrance Orientation

#### A. FAÇADE ORIENTATION

*i. Setbacks*—Align front facades of new buildings with front facades of adjacent buildings where a consistent setback has

been established along the street frontage. Use the median setback of buildings along the street frontage where a variety of

setbacks exist. Refer to UDC Article 3, Division 2. Base Zoning Districts for applicable setback requirements.

*ii. Orientation*—Orient the front façade of new buildings to be consistent with the predominant orientation of historic buildings along the street frontage.

#### **B. ENTRANCES**

*i. Orientation*—Orient primary building entrances, porches, and landings to be consistent with those historically found along the street frontage. Typically, historic building entrances are oriented towards the primary street.

#### 2. Building Massing and Form

#### A. SCALE AND MASS

*i. Similar height and scale*—Design new construction so that its height and overall scale are consistent with nearby historic buildings. In residential districts, the height and scale of new construction should not exceed that of the majority of historic buildings by more than one-story. In commercial districts, building height shall conform to the established pattern. If there is no more than a 50% variation in the scale of buildings on the adjacent block faces, then the height of the new building shall not exceed the tallest building on the adjacent block face by more than 10%.

*ii. Transitions*—Utilize step-downs in building height, wall-plane offsets, and other variations in building massing to provide a visual transition when the height of new construction exceeds that of adjacent historic buildings by more than one-half story.

*iii. Foundation and floor heights*—Align foundation and floor-to-floor heights (including porches and balconies) within one foot of floor-to-floor heights on adjacent historic structures.

#### **B. ROOF FORM**

*i. Similar roof forms*—Incorporate roof forms—pitch, overhangs, and orientation—that are consistent with those predominantly found on the block. Roof forms on residential building types are typically sloped, while roof forms on nonresidential

building types are more typically flat and screened by an ornamental parapet wall.

*ii. Façade configuration*—The primary façade of new commercial buildings should be in keeping with established patterns. Maintaining horizontal elements within adjacent cap, middle, and base precedents will establish a consistent street wall through the alignment of horizontal parts. Avoid blank walls, particularly on elevations visible from the street.

No new façade should exceed 40 linear feet without being penetrated by windows, entryways, or other defined bays.

#### D. LOT COVERAGE

*i. Building to lot ratio*—New construction should be consistent with adjacent historic buildings in terms of the building to

lot ratio. Limit the building footprint for new construction to no more than 50 percent of the total lot area, unless adjacent

historic buildings establish a precedent with a greater building to lot ratio.

3. Materials and Textures

#### A. NEW MATERIALS

i. *Complementary materials*—Use materials that complement the type, color, and texture of materials traditionally found

in the district. Materials should not be so dissimilar as to distract from the historic interpretation of the district. For example, corrugated metal siding would not be appropriate for a new structure in a district comprised of homes with wood

siding.

*ii. Alternative use of traditional materials*—Consider using traditional materials, such as wood siding, in a new way to provide visual interest in new construction while still ensuring compatibility.

*iii. Roof materials*—Select roof materials that are similar in terms of form, color, and texture to traditionally used in the district.

*iv. Metal roofs*—Construct new metal roofs in a similar fashion as historic metal roofs. Refer to the Guidelines for Alterations and Maintenance section for additional specifications regarding metal roofs.

*v. Imitation or synthetic materials*—Do not use vinyl siding, plastic, or corrugated metal sheeting. Contemporary materials not traditionally used in the district, such as brick or simulated stone veneer and Hardie Board or other fiberboard siding, may be appropriate for new construction in some locations as long as new materials are visually similar

to the traditional material in dimension, finish, and texture. EIFS is not recommended as a substitute for actual stucco.

#### 4. Architectural Details

#### A. GENERAL

*i. Historic context*—Design new buildings to reflect their time while respecting the historic context. While new construction should not attempt to mirror or replicate historic features, new structures should not be so dissimilar as to distract from or diminish the historic interpretation of the district.

*ii. Architectural details*—Incorporate architectural details that are in keeping with the predominant architectural style along the block face or within the district when one exists. Details should be simple in design and should complement, but

not visually compete with, the character of the adjacent historic structures or other historic structures within the district. Architectural details that are more ornate or elaborate than those found within the district are inappropriate.

*iii. Contemporary interpretations*—Consider integrating contemporary interpretations of traditional designs and details for

new construction. Use of contemporary window moldings and door surroundings, for example, can provide visual interest

while helping to convey the fact that the structure is new. Modern materials should be implemented in a way that does not

distract from the historic structure.

5. Garages and Outbuildings

#### A. DESIGN AND CHARACTER

*v. Garage doors*—Incorporate garage doors with similar proportions and materials as those traditionally found in the district.

6. Mechanical Equipment and Roof Appurtenances

#### A. LOCATION AND SITING

*i. Visibility*—Do not locate utility boxes, air conditioners, rooftop mechanical equipment, skylights, satellite dishes, and other roof appurtenances on primary facades, front-facing roof slopes, in front yards, or in other locations that are clearly

visible from the public right-of-way.

*ii. Service Areas*—Locate service areas towards the rear of the site to minimize visibility from the public right-of-way.

#### **B. SCREENING**

*i. Building-mounted equipment*—Paint devices mounted on secondary facades and other exposed hardware, frames, and piping to match the color scheme of the primary structure or screen them with landscaping.

*ii. Freestanding equipment*—Screen service areas, air conditioning units, and other mechanical equipment from public view using a fence, hedge, or other enclosure.

*iii. Roof-mounted equipment*—Screen and set back devices mounted on the roof to avoid view from public right-of-way. Historic Design Guidelines, Chapter 5, Guidelines for Site Elements

#### **B. NEW FENCES AND WALLS**

*i. Design*—New fences and walls should appear similar to those used historically within the district in terms of their scale,

transparency, and character. Design of fence should respond to the design and materials of the house or main structure. *ii. Location*—Avoid installing a fence or wall in a location where one did not historically exist, particularly within the front yard. The appropriateness of a front yard fence or wall is dependent on conditions within a specific historic district.

New front yard fences or wall should not be introduced within historic districts that have not historically had them. *iii. Height*—Limit the height of new fences and walls within the front yard to a maximum of four feet. The

appropriateness of a front yard fence is dependent on conditions within a specific historic district. New front yard fences should not be introduced within historic districts that have not historically had them. If a taller fence or wall existed historically, additional height may be considered. The height of a new retaining wall should not exceed the height of the slope it retains.

*iv. Prohibited materials*—Do not use exposed concrete masonry units (CMU), Keystone or similar interlocking retaining

wall systems, concrete block, vinyl fencing, or chain link fencing.

*v. Appropriate materials*—Construct new fences or walls of materials similar to fence materials historically used in the district. Select materials that are similar in scale, texture, color, and form as those historically used in the district, and that

are compatible with the main structure. Screening incompatible uses—Review alternative fence heights and materials for

appropriateness where residential properties are adjacent to commercial or other potentially incompatible uses.

3. Landscape Design

#### A. PLANTINGS

*i. Historic Gardens*— Maintain front yard gardens when appropriate within a specific historic district.

*ii. Historic Lawns*—Do not fully remove and replace traditional lawn areas with impervious hardscape. Limit the removal

of lawn areas to mulched planting beds or pervious hardscapes in locations where they would historically be found, such as along fences, walkways, or drives. Low-growing plantings should be used in historic lawn areas; invasive or large-scale

species should be avoided. Historic lawn areas should never be reduced by more than 50%.

*iii. Native xeric plant materials*—Select native and/or xeric plants that thrive in local conditions and reduce watering usage. See UDC Appendix E: San Antonio Recommended Plant List—All Suited to Xeriscape Planting Methods, for a list

of appropriate materials and planting methods. Select plant materials with a similar character, growth habit, and light requirements as those being replaced.

*iv. Plant palettes*—If a varied plant palette is used, incorporate species of taller heights, such informal elements should be

restrained to small areas of the front yard or to the rear or side yard so as not to obstruct views of or otherwise distract from the historic structure.

*v. Maintenance*—Maintain existing landscape features. Do not introduce landscape elements that will obscure the historic

structure or are located as to retain moisture on walls or foundations (e.g., dense foundation plantings or vines) or as to cause damage.

#### B. ROCKS OR HARDSCAPE

*i. Impervious surfaces* —Do not introduce large pavers, asphalt, or other impervious surfaces where they were not historically located.

*ii. Pervious and semi-pervious surfaces*—New pervious hardscapes should be limited to areas that are not highly visible, and should not be used as wholesale replacement for plantings. If used, small plantings should be incorporated into the design.

*iii. Rock mulch and gravel* - Do not use rock mulch or gravel as a wholesale replacement for lawn area. If used, plantings

should be incorporated into the design.

#### D. TREES

*i. Preservation*—Preserve and protect from damage existing mature trees and heritage trees. See UDC Section 35-523 (Tree Preservation) for specific requirements.

*ii. New Trees* – Select new trees based on site conditions. Avoid planting new trees in locations that could potentially cause damage to a historic structure or other historic elements. Species selection and planting procedure should be done in

accordance with guidance from the City Arborist.

5. Sidewalks, Walkways, Driveways, and Curbing

#### A. SIDEWALKS AND WALKWAYS

*i. Maintenance*—Repair minor cracking, settling, or jamming along sidewalks to prevent uneven surfaces. Retain and repair historic sidewalk and walkway paving materials—often brick or concrete—in place.

*ii. Replacement materials*—Replace those portions of sidewalks or walkways that are deteriorated beyond repair. Every effort should be made to match existing sidewalk color and material.

*iii. Width and alignment*—Follow the historic alignment, configuration, and width of sidewalks and walkways. Alter the historic width or alignment only where absolutely necessary to accommodate the preservation of a significant tree. *iv. Stamped concrete*—Preserve stamped street names, business insignias, or other historic elements of sidewalks and

walkways when replacement is necessary.

*v. ADA compliance*—Limit removal of historic sidewalk materials to the immediate intersection when ramps are added to

address ADA requirements.

#### **B. DRIVEWAYS**

*i. Driveway configuration*—Retain and repair in place historic driveway configurations, such as ribbon drives. Incorporate

a similar driveway configuration—materials, width, and design—to that historically found on the site. Historic driveways

are typically no wider than 10 feet. Pervious paving surfaces may be considered where replacement is necessary to increase stormwater infiltration.

*ii. Curb cuts and ramps*—Maintain the width and configuration of original curb cuts when replacing historic driveways. Avoid introducing new curb cuts where not historically found.

#### 7. Off-Street Parking

#### A. LOCATION

*i. Preferred location*—Place parking areas for non-residential and mixed-use structures at the rear of the site, behind primary structures to hide them from the public right-of-way. On corner lots, place parking areas behind the primary structure and set them back as far as possible from the side streets. Parking areas to the side of the primary structure are acceptable when location behind the structure is not feasible. See UDC Section 35-310 for district-specific standards. *ii. Front*—Do not add off-street parking areas within the front yard setback as to not disrupt the continuity of the streetscape.

*iii. Access*—Design off-street parking areas to be accessed from alleys or secondary streets rather than from principal streets whenever possible.

#### **B. DESIGN**

*i. Screening*—Screen off-street parking areas with a landscape buffer, wall, or ornamental fence two to four feet high—or

a combination of these methods. Landscape buffers are preferred due to their ability to absorb carbon dioxide. See UDC Section 35-510 for buffer requirements.

*ii. Materials*—Use permeable parking surfaces when possible to reduce run-off and flooding. See UDC Section 35-526(j)

#### for specific standards.

*iii. Parking structures*—Design new parking structures to be similar in scale, materials, and rhythm of the surrounding historic district when new parking structures are necessary.

#### FINDINGS:

- a. The applicant has proposed to construct a two story house on the vacant lot at 1111 E Crockett in the Dignowity Hill Historic District. The lot is located mid-block between N Olive Street and N Pine Street. The historic structure was damaged by fire in April 2016. An emergency demolition permit was obtained from Development Services Department on April 7, 2016.
- b. CONCEPTUAL APPROVAL The applicant received conceptual approval at the May 17, 2017, Historic and Design Review Commission hearing with the following stipulations:
  - i. That the applicant propose a foundation height that is consistent with the Guidelines and historic examples found on this block of E Crockett. *The applicant has noted a foundation height of 18 to 21 inches*.
  - ii. That the applicant provide a street elevation and additional massing information to determine the new construction's impact on the neighboring historic structures. *The applicant has provided a street elevation and additional massing documents*.
  - iii. That the applicant incorporate window openings that are consistent with the Guidelines. *The applicant has amended previously designed window openings to feature traditional dimensions.*

- *iv.* That the applicant install wood windows that that are to include traditional dimensions and profiles, be recessed within the window frame, feature traditional materials or appearance and feature traditional trim and sill details. *The applicant has proposed block framed vinyl windows*.
- v. That the applicant provide a column detail noting the installation of a capital and base.
- vi. That the applicant screen all mechanical equipment. *The applicant has noted the screening of the mechanical equipment on the updated site plan.*
- vii. That the applicant incorporate a front yard sidewalk. *The applicant has noted the installation of front yard sidewalks on the updated site plan.*
- viii. That the applicant provide a landscaping plan noting landscaping materials. *The applicant has noted the installation of grass and new trees.*
- ix. That the applicant provide additional information regarding the proposed carport's materials. *The carport has been removed from the proposed scope of work.*
- c. The proposed new construction at 1111 E Crockett has been proposed in addition to new construction at 1115 E Crockett. Currently, these are two separate lots; however, the applicant has proposed to remove the lot line through a certificate of determination.
- d. SETBACKS & ORIENTATION According to the Guidelines for New Construction, the front facades of new buildings are to align with front facades of adjacent buildings where a consistent setback has been established along the street frontage. Additionally, the orientation of new construction should be consistent with the historic examples found on the block. The applicant has proposed a setback of approximately twenty-six (26) feet.
- e. ENTRANCES According to the Guidelines for New Construction 1.B.i., primary building entrances should be oriented towards the primary street. The applicant has proposed to orient the primary entrance toward E Crockett. This is consistent with the Guidelines.
- f. SCALE & MASS Per the Guidelines for New Construction 2.A.i., a height and massing similar to historic structures in the vicinity of the proposed new construction should be used. In residential districts, the height and scale of new construction should not exceed that of the majority of historic buildings by more than one-story. There are examples of two story historic structures in the vicinity including one on the northwest corner of N Olive and E Crockett; however, this block of E Crockett is entirely composed of single story structures. The applicant has provided a street section noting the proposed new construction in relationship with the existing, historic structures. Staff finds the proposed new construction's massing and height to be appropriate.
- g. FOUNDATION & FLOOR HEIGHTS According to the Guidelines for New Construction 2.A.iii., foundation and floor height should be aligned within one (1) foot of neighboring structure's foundation and floor heights. Historic structures on this block feature foundation heights of approximately eighteen to thirty inches. The applicant has proposed a foundation height ranging from eighteen to twenty-one inches. This is consistent with the Guidelines.
- h. ROOF FORM The applicant has proposed a front gabled roof. Gabled roofs are featured throughout the Dignowity Hill Historic District as well as on the majority of the historic structures on E Crockett. This is consistent with the Guidelines.
- i. WINDOW & DOOR OPENINGS Per the Guidelines for New Construction 2.C.i., window and door openings with similar proportions of wall to window space as typical with nearby historic facades should be incorporated into new construction. The applicant has proposed window openings on each façade that feature proportions similar to those found historically throughout the Dignowity Hill Historic District. This is consistent with the Guidelines.
- j. WINDOW & DOOR OPENINGS The applicant has proposed a small fixed window on the front façade that is located in an upstairs bathroom. Staff finds that this window should be a sash window like other similarly sized windows.
- k. LOT COVERAGE Per the Guidelines, the building footprint for new construction should be no more than fifty (50) percent of the size of the total lot area. The proposed new construction is consistent with the Guidelines for New Construction 2.D.i.
- 1. MATERIALS Regarding materials, the applicant has proposed first floor materials to include horizontally oriented Hardi siding, a second floor of board and batten Hardi siding, eight inch square cedar columns, hog wire and cedar guardrails, cedar timber trusses and a standing seam metal roof. The applicant has noted that the proposed Hardi siding will feature a smooth finish. Staff finds that the horizontally oriented Hardi siding should feature an exposure of four inches, that the board and batten siding feature boards that are twelve (12) inches wide with battens that are  $1 \frac{1}{2}$  wide, that the standing seam metal roof feature panels that are 18 to 21 inches wide,

seams are 1 to 2 inches in height, a crimped ridge seam or low profile ridge cap and a standard galvalume finish. A large profiled ridge cap shall not be used.

- m. WINDOW MATERIALS The applicant has proposed block framed vinyl windows. The applicant has provided staff with a wall section noting an installation depth of one inch. Staff finds that the applicant should provide additional product information for the windows including a product specification sheet that notes window sash profiles, consistency with historic window profiles, colors and track colors.
- n. ARCHITECTURAL DETAILS New building should be designed to reflect their time while representing the historic context of the district. Additionally, architectural details should be complementary in nature and should not detract from nearby historic structures. Staff finds the proposed architectural details to be generally appropriate and consistent with the Guidelines. The applicant has incorporated the double height porch within the massing of the proposed structure, has proposed roof forms that are consistent with those found throughout the neighborhood and has proposed appropriate materials.
- o. COLUMN DESIGN The applicant has proposed eight in square cedar columns. Given the proposed height and porch massing, staff finds the proposed columns to feature an appropriate size; however, each column should feature both a capital and base.
- p. MECHANICAL EQUIPMENT Per the Guidelines for New Construction 6., all mechanical equipment should be screened from view at the public right of way. The applicant has noted the screening of all mechanical equipment.
- q. DRIVEWAY To the east 1111 E Crockett, the applicant has proposed to install a ribbon strip driveway. The applicant has noted the removal of an existing curb cut and the installation of a new curb cut and apron to facilitate vehicular access to this driveway. The applicant has noted a total width of nine feet and materials of concrete with decomposed granite between each ribbon strip. This is consistent with the Guidelines.
- r. SIDEWALK The applicant has proposed to locate a front yard, concrete sidewalk to connect from the proposed front porch to the sidewalk at the public right of way. Staff finds this installation appropriate; however, the proposed sidewalk should feature a width consistent with those on this block of E Crockett.
- s. LANDSCAPING The applicant has noted landscaping materials to include decomposed granite, grass throughout the traditional front and rear yard lawn areas and new trees. This is appropriate and consistent with the Guidelines.
- t. FENCING Front yard fences are found along this block of E Crockett; however, the majority of those that currently exist are chain link fences. The applicant has noted the installation of a cattle panel fence. Staff finds the installation of this fence appropriate; however, the height is not to exceed four (4) feet in height in the front yard.

#### **RECOMMENDATION:**

Staff recommends approval based on findings a through s with the following stipulations:

- i. That the applicant provide additional product information for the windows including a product specification sheet that notes window sash profiles, consistency with historic window profiles, colors and track colors for approval by staff as noted in finding m.
- ii. That the proposed front yard fencing does not exceed four (4) feet in height as noted in finding t.
- iii. That the applicant install a sash window in the upstairs bathroom on the front façade as noted in finding j.
- iv. That all Hardi siding feature a smooth finish, that the horizontally oriented Hardi siding should feature an exposure of four inches, that the board and batten siding feature boards that are twelve (12) inches wide with battens that are  $1 \frac{1}{2}$ " wide, that the standing seam metal roof feature panels that are 18 to 21 inches wide, seams are 1 to 2 inches in height, a crimped ridge seam or low profile ridge cap and a standard galvalume finish. A large profiled ridge cap shall not be used.

#### **CASE MANAGER:**

Edward Hall





## Flex Viewer

Powered by ArcGIS Server

Printed:May 05, 2017

The City of San Antonio does not guarantee the accuracy, adequacy, completeness or usefulness of any information. The City does not warrant the completeness, timeliness, or positional, thematic, and attribute accuracy of the GIS data. The GIS data, cartographic products, and associated applications are not legal representations of the depicted data. Information shown on these maps is derived from public records that are constantly undergoing revision. Under no circumstances should GIS-derived products be used for final design purposes. The City provides this information on an "as is" basis without warranty of any kind, express or implied, including but not limited to warranties of merchantability or fitness for a particular purpose, and assumes no responsibility for anyone's use of the information.











#### NARRATIVE – 1111 & 1115 E. CROCKETT ST.

Requesting final approval to construct two two-story single family houses on two vacant lots. The proposed design will include a driveway for each house, one accessed from E. Crockett and another from E. Lynn St. Driveways will be concrete ribbons with crushed gravel in between. A new walkway will connect the front door of each house to the sidewalk. The rest of the site landscaping surface will be grass. Two new trees will be planted as shown on site plan.

The new houses will be pushed back to align with the historic houses on the north side of the street. The foundations will be elevated so that they are within one foot of the highest foundation elevation on the existing houses.

The structures will have a galvalume standing seam metal roof, a combination of smooth Hardie plank and board and batten siding, block frame vinyl windows, and a wood and wire railing at the front porches. The proposed vinyl windows will be installed as further into the opening as possible using wood stops to achieve a similar installation as historic windows.

A 6ft. tall wood privacy fence will be installed in the rear yards, and a 4ft. wood and cattle wire fence will be installed in the front yards. The majority of houses on this block have a front yard fence so the proposed installation will not disrupt the continuity of the street.







Architecture   1218 E. EUCL SAN ANTONIO TEL. 210.20	D, TX 78212 01.3637 @STUDIOZIGA.C	reservation
NEW CONSTRUCTION TOWNHOMES	1111 & 1115 E. CROCKETT ST. SAN ANTONIO, TX 78202	HENNEKE FINANCIAL GROUP
REV FOR ( PE	RAWING FOR IEW ONLY. NO CONSTRUCTI RMITTING OF EGULATORY APPROVAL	OT ON,
ALL RIGHTS R AND ITS REPR PROPERTY OF PLLC. IT MAY N PUBLISHED, OF THEWRITTEN ARCHITECTUF	ARCHITECTURE S ESERVED. THIS D ODUCTIONS ARE ZIGA ARCHITECT NOT BE REPRODU R USED IN ANY W PERMISSION OF Z RE STUDIO, PLLC. ISSUE E DESC	Rawing The Iure Studio, Jced, Ay Without Ziga
	SURVEYS	
	0 //	17-111 7.14.2017 AMZ / FJZ FJZ 24683

ROOF LINE ABOVE -

(N) DESIRED MECH. -SYSTEMS LOCATION

(N) 6' CEDAR <sup>—</sup> PRIVACY FENCE

WIRE FRONT YARD FENCE PER EXHIBITS, TYPICAL







A200

Architecture   Ir 1218 E. EUCLIE SAN ANTONIO TEL. 210.201	, TX 78212 1.3637 STUDIOZIGA.C	reservation
NEW CONSTRUCTION TOWNHOMES	1111 & 1115 E. CROCKETT ST. SAN ANTONIO, TX 78202	HENNEKE FINANCIAL GROUP
FOR C FOR C PEF	AWING FOR EW ONLY. NO ONSTRUCTI MITTING OF EGULATORY APPROVAL	ON,
ALL RIGHTS RE AND ITS REPRO PROPERTY OF 2 PLLC. IT MAY NO PUBLISHED,OR THEWRITTEN P	RCHITECTURE S SERVED. THIS D DUCTIONS ARE ZIGA ARCHITECT OT BE REPRODU USED IN ANY W ERMISSION OF 2 E STUDIO, PLLC.	RAWING THE FURE STUDIO, ICED, AY WITHOUT
# DATE 1 07/14/		<b>RIPTION</b> RC SET
PROP	OSED FLO	DOR
PLANS PROJECT NO.	S - UNIT A	
DATE: DRAWN BY: REVIEWED BY PROJECT ARC FELIX J. ZIG TEXAS LI	/: CHITECT:	AMZ / FJZ FJZ
ŀ	00	



A200







SCALE: 3/16"=1'=0"

3 NORTH ELEVATION SCALE: 3/16"=1'=0"











# 2 WINDOW HEAD DETAIL SCALE: 3"=1'-0"



# **3** WINDOW SILL DETAIL SCALE: 3"=1'-0"

1X WOOD DRIP CAP

FLASHING

1X WOOD TRIM

1X BLIND STOP

BACKER ROD AND SEALANT

2X WOOD SILL

1X WOOD TRIM



















# View of E. Crockett Street facing West – showing street sloping down towards downtown





View of project site-showing elevation change between neighboring property and site

## Front Setbacks along E. Crockett St.



Approx. 4 ft.



Approx. 22 ft.



Approx. 22 ft.



Approx. 20 ft.

Front setbacks along the north side of the street range from 4ft to 22 ft. The remaining historic structures have a setback of 20-22ft. The proposed front setback will follow the current setback pattern of the historic structures on the street.

## Street Section





Foundation Heights along E. Crockett St.



Approx. 24 in.



Approx. 18 in.



Approx. 24 in.



Approx. 21 in.



Approx. 18 in.

### Foundation Heights along E. Crockett St.



Approx. 24 in.



Approx. 18 in.





Approx. 24 in.

Approx. 30 in.

Due to the ground slope, foundation heights are not consistent throughout this block of E. Crockett St. The lowest measurement at the front entrance is at approximately 18in and the highest at approximately 30in. The majority of houses have a 24in height. The proposed design is elevated by 18in which is within one foot of the majority of houses on the block as recommended by the guidelines.





PROPOSED 6'-0" CEDAR PRIVACY FENCE AT REAR & SIDE YARDS

## PROPOSED 4'-0" CATTLE WIRE AND CEDAR FENCE AT FRONT YARD/RAILINGS



# **DWELLING A**

BODY SW 7015 REPOSE GRAY



CEDAR COLUMNS

STANDING SEAM METAL ROOF



HARDIE ARTISAN LAP SIDING, SMOOTH FINISH WITH 4" EXPOSURE



HARDIE BOARD AND BATTEN SIDING



## DWELLING B

BODY SW 0017 CLASSIC FRENCH GRAY





CEDAR COLUMNS STANDING SEAM METAL ROOF



HARDIE ARTISAN V-RUSTIC SIDING, SMOOTH FINISH



HARDIE BOARD AND BATTEN SIDING

